

2017 Parker County Peach Festival

Electricity Guidelines

The following are guidelines for the 120 Volt Power and the 220 Volt Power options for vendors who have requested and paid for electricity at the 2016 Parker County Peach Festival. This is a contract; you must sign and date the contract before you will be allowed to have electricity. Your placement is not official until this form is completed and returned to our office via mail, email or fax. A copy of this contract will be in Peach Central during the festival set-up and during festival hours. A copy will also be given to the on-duty electrician. *If you try to access power that you did not purchase or connect improperly to the power source, you will be disconnected before or during the festival.*

If you need 120 Volt Power:

- ◆ Each outlet provided will accommodate 16 amps total.
 - 2 Refrigerators requiring 8 amps each will be 16 amps total.
 - 3 bun warmers pulling 5 amps each will be 15 amps total.
- ◆ You CANNOT total over 16 amps per receptacle. Most appliances are labeled on the back to show the amperage usage. It is your responsibility to know this before you set up at the festival and you must request the correct amount of receptacles in advance.
- ◆ **Your extension cords CANNOT be connected together to make a cord long enough to reach a receptacle.** The Fire Marshall will disconnect the morning of the festival if you do not comply with this statement. Each vendor is required to provide a 100 foot heavy duty extension cord.

If you ask for 220 Volt Power:

- ◆ The power cord from your trailer to the breaker box must be able to connect directly to the breaker without a male plug (we connect directly to the breaker).
- ◆ If your power cord is not able to connect directly into the breaker, you must provide a six (6) foot cable with a female receptacle on one end and loose wire on the other end to connect directly to the breaker.
- ◆ You must provide at least a 50 foot power cord. You will not be allowed to plug cords into each other to make it long enough. The Fire Marshall will disconnect the morning of the festival if you do not comply with this statement.

The 220 Volt power is **not** interchangeable with the 120 Volt power so please request the proper electricity supply. Thank you for your help in completing the following information about your electricity needs. We are requesting this information for the 2017 Parker County Peach Festival to ensure all vendors have adequate supply of electricity and to provide a safe environment for all vendors and guests. If you have any questions regarding the electricity descriptions above, please contact the Weatherford Chamber of Commerce at 817-596-3801.

Please complete the following and return to the Weatherford Chamber of Commerce:

***You are receiving this contract because you have requested and paid for electricity**

Parker County Peach Festival

401 Fort Worth Hwy

Weatherford, TX 76086

Fax: 817-613-9216

Phone: 817-596-3801

Email: gmartinez@weatherford-chamber.com

I need ____ receptacles of 120 Volt Power (\$30 each) = Total \$_____

I need ____ receptacles of 220 Volt Power (\$40 each) = Total \$_____

Please list ALL electrical appliances that you intend to use during the festival so that we may verify your Voltage needs:

Business Name

Contact Name

Phone Number

Email

Signature

Date

#parkercountypeachfestival



**Follow us on
Instagram**

Follow Us On *Pinterest*

Office Use Only

Date Received: _____